


## The Rural Municipality of Elton

<b>REFERENCE:</b>	Utility	<b>AUTHORITY:</b>	Council
<b>SUBJECT:</b>	Minimum Utility PSI	<b>EFFECTIVE DATE:</b>	August 15, 2017
<b>ADOPTED BY RESOLUTION NO. &amp; DATE:</b>	2017-252	<b>NUMBER OF PAGES:</b>	1
<b>AMENDED BY RESOLUTION NO. &amp; DATE:</b>		<b>REEVE'S SIGNATURE FOR APPROVAL</b>	

### **POLICY DESCRIPTON:**

Being a policy to provide for minimum water pressure in the Elton Rural Waterline system, operating under the Elton Utility.

- Minimum pressure from the system shall be 45 pounds per square inch (PSI)
- Following a concern with pressure, Elton Utility shall investigate possible methods to increase pressure to minimums.
- Should adjustments at booster and/or pressure reducing stations not address the pressure concerns, the following steps may be taken at the discretion of the CAO:
  - Where system pressures provide the stated minimum, the building has the option to install an in-house pressure booster valve at their cost.
  - Where system pressures do NOT provide the stated minimum, an in-house pressure booster valve will be **installed** at the cost of the Elton Utility.
- All installations of in-house pressure boosting systems must be inspected by Elton Utility staff.